



## Certification Record

CUSTOMER	CLASS	FILE
Interpower Corporation 100 Interpower Ave, Oskaloosa IA 52577-0115 USA	<u>6225-01</u> FUSEHOLDER ASSEMBLIES-  <b>Refer to Class Description for program details</b>	73106

The following fuseholder assemblies have been examined in accordance with Electrical Certification Notice 552 except Cl 4.1.1:

- Extractor fuseholder assemblies for through-the panel mounting, Types 80910010, 80910020, 80910030, 80910040, 80910050, 80910060, 80910070, 80910080, 80910090, 80910100, 80910110, 80910120, (for fuses 1/4 in by 1-1/4 in) and (for fuses 5mm by 20mm), 16A and less, 250V ac and less. Assemblies are composed of body Types 809 (w suffixes).
- Types 80910300, and 80910310, fuseholder assemblies, 16A and less, 250V ac and less, extractor type, for through panel mounting, thread mount or snap-in, solder or quick connect terminals, by use of a fuse carrier for use with 1/4 in by 1-1/4 in or 5mm by 20mm cartridge fuses.

Note: All fuseholder assemblies are for use with Certified fuses and only as component parts of equipment where the acceptability is determined by the Canadian Standards Association. "Tron" fuseholders are for use in locations where they are required to be disconnected from the supply before access is permitted.

---

Copyright © 2007 CSA International. All rights reserved.