



Certificate of Compliance

Certificate: 1117379

Master Contract: 161136

Project: 2665028

Date Issued: October 2, 2013

Issued to: Interpower Corporation
100 Interpower Ave
Oskaloosa, IA 52577-0115
USA
Attention: Joe Caligiuri

The products listed below are eligible to bear the CSA Mark shown



Johann Borabon

Issued by: Johann Borabon

PRODUCTS

CLASS 5842 02 - CORD SETS - Power Supply Cords

Special-use power supply cords with male plug cap, Cat No E02 moulded on flexible cords, size 14/3-18/3 AWG, types SJT, SJT shielded, SVT, SVT shielded, rated 15A max, 250V.

Special-use power supply cords with male plug cap, Cat No E02 moulded on flexible cord size 18/3 AWG, type SPT-2, rated 10A, 250V.

Notes:

- Supplied only to manufacturers, as components, for the assembly of Certified electrical equipment, where the suitability and acceptability of the combination is to be determined in the end use.
- Maximum current rating of each device is limited to 15A or up to the maximum permissible ampacity of the flexible cord size, whichever is lower, in accordance with the Code.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 21-95 - Cord Sets and Power Supply Cords

CSA Std C22.2 No.182.3-M1987 - Special Use Attachment Plugs, Receptacles, and Connectors

INFORMS: Cord Sets No. 7A - Production-Line Test for Cord Sets and Power-Supply Cords



Supplement to Certificate of Compliance

Certificate: 1117379

Master Contract: 161136

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2665028	Oct 2, 2013	Addition of flexible cord sizes, 17 and 15 AWG to Cat No E02..
2455970	Sep 16, 2011	Alternate body moulding material PVC Apex 4112. Class 5842 02, C22.2 No.21-95.
2413179	May 4, 2011	Addition of flexible cord Type SPT-2, 18/3c AWG to Cat No E02; Class 5842 02, C22.2 No.21-95.
1698828	Sep 28, 2005	Addition of two alternate bridge materials Ultramid PA6/6 A3X2G5 (manufactured by Basf), Badamid PA6/6 C70 TM-Z3 FR (manufactured by Bada) for plug cap E02.
1615928	Mar 31, 2005	Update to report 1117379 to include alternate bridge Polyamide PA6/6 A70GF30 (manufactured by Bada AG), Polyamide PA6/6 A700G25 (manufactured by Bergmann GmbH) for plug cap cat. no. E02

History

1117379	November 29, 2000	Original Certification, PS cord with special-use male plug cap, Cat No E02 moulded with Nos 14/3-18/3 AWG flexible cords
---------	-------------------	--