

Terminal Blocks - Component

COMPANY

HEAVY POWER CO LTD

7 LANE 106 WUKUNG 3RD RD

WUKU DISTRICT

NEW TAIPEI, 248 Taiwan

E152546

Type	Wire Range	Wire Type	FW	TQ Lb In.	V	A	UG	CA
PA8, PA8DS	12-22 Sol/Str	Cu	2	3.5	300	20	B	1,2(105),4,#
PA8P, PA8PDS	12-22	Cu	2	3.5	600	20	B,C	1,2(105),4,#
PA10	10-22 sol, 10-14 str	Cu	2	4.4	300	30	B	1,2(105),4,#
PA10P	10-22 sol, 10-14 str	Cu	2	4.4	600	30	B,C	1,2(105),4,#
PA10DS	12-22, sol/str,10 sol	Cu	2	4.4	300	30	B,C	1,2(105),4,#
PA10PDS	12-22, sol/str,10 sol	Cu	2	4.4	600	30	B,C	1,2(105),4,#
PA0011, PA0021	14-26	Cu	2	2	300	10	B,D	2(75),4,#
PA0012, PA0022	14-26	Cu	2	2	300	10	B,D	1,2(75),4,#
PA001, PA002	14-26	Cu	2	2	300	10	B,D	2(115),4
PA0010, PA0020	14-26	Cu	2	2	300	10	B,D	1,2(115),4
PA001B	14-26	Cu	2	3.54	300	10	B,D	2(75),4,#
PA14, PA14DS	8-20	Cu	2	12	150	50	C	1,2(105)#,3
	8-20	Cu	2	12	300	50	B	1,2(105)#,3
PA12, PA12DS	10-22	Cu	2	7	300	35	B	1,2(105)#3
PA0031, PA0071	14-18	Cu	2	4.4	300	15	B	2(75),4
					300	Note A	D	






Feedback

PA0032, PA0072	14-18	Cu	2	4.4	300	15	B	1,2(75),4
					300	Note A	D	
PA003, PA007	14-18	Cu	2	4.4	300	15	B	2(115), 4
					300	Note A	D	
PA0030, PA0070	14-18	Cu	2	4.4	300	15	B	1,2(115), 4
					300	Note A	D	
PA11	14-18 sol.screwside	Cu	2	4.5	300	12	B,D	1,2(105)4
	16-20 sol.push-inside							
PA16	6-14	Cu	1,2	10	150	65	C	2(105),4
			1,2	10	300	68	B	
PA18	4-12	Cu	2	18	300	85	B,C	2(105),4
			1	18	300	87	B,C	
PA9, PA9F, PA9DS, PA9FDS	12-22 sol/str	Cu	2	4.4	600	30	B,C	2(130),4
PA9X	12-22 sol/str	Cu	2	4.4	300	20	B	2(115),1,4
					300	NOTE A	D	
PA9XP	12-22 sol/str	Cu	2	4.4	300	20	B	2(65),1,4
					300	NOTE A	D	
PA7, PA7F, PA7DS, PA7FDS	12-22 sol/str	Cu	2	3.5	300	20	B	2(85),4
					300	10	D	
					150	15	D	
PA7X, PA20, PA21	12-22- sol/str	Cu	2	3.5	300	20	B	1,2(105),4
					300	10	D	1,2(105),4
					150	15	D	1,2(105),4
PA7XP, PA20P, PA21P	12-22 sol/str	Cu	2	3.5	300	20	B	1,2(65),4
					300	10	D	1,2(65),4
					150	15	D	1,2(65),4
PA30, PA31	22-10 AWG sol, 10-14 AWG, str	Cu	2	4.4	300	25	B, C, D	1,2(105),4
PA30P, PA31P	22-10 AWG sol, 10-14 AWG, str	Cu	2	4.4	300	25	B, C, D	1,2(65),4
PA40, PA41	10-16 str, 10-18 sol	Cu	2	7	300	30	B, C	1,2(105),4

	10-16 str, 10-18 sol	Cu	2	7	300	NOTE A	D	1,2(105),4
PA40P, PA41P	10-16 str, 10-18 sol	Cu	2	7	300	30	B, C	1,2(65),4
	10-16 str, 10-18 sol	Cu	2	7	300	NOTE A	D	1,2(65),4
PA20DS	22-12 Sol, 22-14 Str	Cu	2	3.5	300	20A (NOTE A)	B,D	1,2(105),4
PA30DS	22-10 Sol, 22-12 Str	Cu	2	4.5	300	25A (NOTE A)	B,D	1,2(105),4
(1) - Cat. Nos. PA40, PA40P, PA41, PA41P may be used at 35A for factory wiring applications only.								
(2) - Cat. Nos. PA40, PA40P may be used only where steel is acceptable for current-carrying parts.								
235	20-14 AWG Sol/Str	Cu	2	—	300	10	B, D ^A	2(115),4
250	24-16 AWG Sol/Str	Cu	2	—	300	5	B, D ^A	2(115),4
RT128	24-12 AWG Sol/Str	Cu	2	3.5	300	20	B, D ^A	2(115),4
PA9C	22-12 AWG Sol/Str	Cu	2	4.4	300	20	B, D	2(115),4

#Unique Conditions of Acceptability — The suitability of conducting a hot wire ignition test shall be determined in end use.

Note A - These limited ratings are applicable to a terminal block for use in or with industrial control equipment whereby the load on any single circuit of the terminal block does not exceed 15 A at 51-150 V, 10 A at 151-300 V, or 5 A at 301-600 V, or the maximum ampere rating, whichever is less.

Marking: Company name or trademarks  or  or  or  or  and catalog designation. (Type, series or catalog designation may appear on shipping carton).

Last Updated on 2023-01-12

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."

Terminal Blocks Certified for Canada - Component

COMPANY

HEAVY POWER CO LTD
 7 LANE 106 WUKUNG 3RD RD
 WUKU DISTRICT
 NEW TAIPEI, 248 Taiwan

E152546







Cat. No.	Wire Range	Wire		TQ	V	A	UG	CA
		Type	Lb In.					
PA0011, PA0021	14-26	Cu	2	300	10		B,D	2(75),#
PA0012, PA0022	14-26	Cu	2	300	10		B,D	1,2(75),#
PA001, PA002	14-26	Cu	2	300	10		B,D	2(115)
PA0010, PA0020	14-26	Cu	2	300	10		B,D	1,2(115)
PA001B	14-26	Cu	3.54	300	10		B,D	2(75),#
PA14, PA14DS	8-20	Cu	12	150	50		C	1,2(105),3
	8-20	Cu	12	300	50		B	1,2(105),3
PA12, PA12DS	10-22	Cu	7	300	35		B	1,2(105)#3
PA0031, PA0071	14-18	Cu	4.4	300	15		B	2(75)
				300	Note A		D	
PA0032, PA0072	14-18	Cu	4.4	300	15		B	1,2(75)
				300	Note A		D	
PA003, PA007	14-18	Cu	4.4	300	15		B	2(115)
				300	Note A		D	
PA0030, PA0070	14-18	Cu	4.4	300	15		B	1,2(115)
				300	Note A		D	
PA11	14-18 sol. screwside	Cu	4.5	300	12		B,D	1,2(105)4
	16-20 sol. push-inside							

PA16	6-14	Cu	10	150	68	C	2(105)
PA16	6-14	Cu	10	300	68	B	2(105)
PA18	4-12	Cu	18	300	87	B,C	2(105)
PA7, PA7F, PA7DS, PA7FDS	12-22 sol/str	Cu	3.5	300	20	B	2(85)
				300	10	D	
				150	15	D	
PA9, PA9F, PA9DS, PA9FDS	12-22 sol/str	Cu	4.4	600	30	B,C	2(130)
PA9X	12-22 sol/str	Cu	4.4	300	20	B	2(115),1
				300	NOTE A	D	
PA9XP	12-22 sol/str	Cu	4.4	300	20	B	2(65),1
				300	NOTE A	D	
PA7X, PA20, PA21	12-22 sol/str	Cu	3.5	300	20	B	1, 2(105)
				300	10	D	1,2(105)
				150	15	D	1,2(105)
PA7XP, PA20P, PA21P	12-22 sol/str	Cu	3.5	300	20	B	1,2(65)
				300	10	D	1,2(65)
				150	15	D	1,2(65)
PA30, PA31	22-10 AWG sol, 10-14 AWG/str	Cu	4.4	300	25	B, C, D	1,2(105)
PA30P, PA31P	22-10 AWG sol, 10-14 AWG/str	Cu	4.4	300	25	B, C, D	1,2(65)
PA40, PA41	10-16 str, 10-18 sol	Cu	7	300	30	B, C	1,2(105)
	10-16 str, 10-18 sol	Cu	7	300	NOTE A	D	1,2(105)
PA40P, PA41P	10-16 str, 10-18 sol	Cu	7	300	30	B, C	1,2(65)
	10-16 str, 10-18 sol	Cu	7	300	NOTE A	D	1,2(65)
PA20DS	22-12 Sol, 22-14 Str	Cu	3.5	300	20A (NOTE A)	B,D	1,2(105)
PA30DS	22-10 Sol, 22-12 Str	Cu	4.5	300	25A (NOTE A)	B,D	1,2(105)
(1) - Cat. Nos. PA40, PA40P may be used only where steel is acceptable for current-carrying parts.							
235	20-14 AWG Sol/Str	Cu	—	300	10	B, D ^A	2(115)
250	24-16 AWG Sol/Str	Cu	—	300	5	B, D ^A	2(115)

RT128	24-12 AWG Sol/Str	Cu	0.4	300	20	B, D ^A	2(115)
PA9C	22-12 AWG Sol/Str	Cu	0.5	300	20	B, D	2(115)

#Unique Conditions of Acceptability — The suitability of conducting a hot wire ignition test shall be determined in end use.

Note A - These limited ratings are applicable to a terminal block for use in or with industrial control equipment whereby the load on any single circuit of the terminal block does not exceed 15 A at 51-150 V, 10 A at 151-300 V, or 5 A at 301-600 V, or the maximum ampere rating, whichever is less.

Marking: Company or trademarks  or  or  or  or  and Recognized Component Mark for Canada, , on the product. Catalog designation, maximum voltage, wire range, and ampere rating appear on the device or in or on the carton.

Last Updated on 2023-01-12

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2023 UL LLC."