

# CERTIFICATE FI 25616 A2

Our Ref. 258556, 277050-1

**Product** Plug, non-rewirable

**Type** 008, with cord H03VV-F 3G0,75  
008, with cord H05VV-F 3G0,75-1-1,5  
009, with cord H03VV-F 3G0,75  
009, with cord H05VV-F 3G0,75-1-1,5

**Trade mark**

**Certificate Holder/Manufacturer** Interpower Corporation  
100 Interpower Avenue Oskaloosa  
IOWA 52577, UNITED STATES

**Technical information** 16 A, 250 V~

**Other information** Standard sheet CEE 7 / VII, for class I equipments  
008: with angled cord entry  
009: with straight cord entry

**The product is certified according to the following standard(s)** IEC 60884-1:2002 (Ed 3) + A1:2006  
SFS 5610:2004 + A1:2008

**Validity** This certificate is valid until 28 July 2015 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue** 28 January 2015

**SGS Fimko Ltd**

**Signature**

Sixten Lökfors  
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at [http://www.sgs.fi/en/Terms\\_and\\_Conditions.aspx](http://www.sgs.fi/en/Terms_and_Conditions.aspx). Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Appendix to Certificate: 25616 A2


**Manufacturing sites**  
Interpower Corporation  
100 Interpower Avenue Oskaloosa  
IOWA 52577, UNITED STATES

Interpower Corporation  
221 South Spruce St., LAMONI  
IA 50140, UNITED STATES

**Additional information**  
The product has certificate NL-19976 issued by DEKRA Certification B.V. in accordance with the CB system.

This certificate replaces previous certificate FI 25616 A1 dated 17 February 2011, due to prolonged validity.


Type 008, Manufacturing place LAMONI:

LA  008  
16A/250~

Type 008, Manufacturing place OSKALOOSA:

 008  
16A/250~

Type 009, Manufacturing place LAMONI:

LA  009  
16A/250~

Type 009, Manufacturing place OSKALOOSA:

 009  
16A/250~

**Our ref.** 258556