

CERTIFICATE

KEMA No.: 2002763.02

Issued to:

Applicant:

Adels-Contact GmbH & Co.K.G.
Buchholzstrasse 40-46
BERGISCH GLADBACH, Germany

Manufacturer/Licensee:

Adels-Contact GmbH & Co.K.G.
Buchholzstrasse 40-46
BERGISCH GLADBACH, Germany

Product : terminal blocks

Trade name : ADELS-CONTACT

Types/models : 500/...

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60998-2-1:1993
- an inspection of the production location according tot CCA Group Operational Document CCA 204
- a certification agreement with the number 900462

KEMA hereby grants the right to use the KEMA certification mark



The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: June 21, 2000

C.M. Boschloo
Certification Manager

© Integral publication of this certificate is allowed



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	terminal blocks
trade name	:	ADELS-CONTACT
types	:	500/...
rated insulation voltage	:	380 V
rated connecting capacity	:	2,5 mm ² , rigid and flexible
ambient temperature	:	T85
connectable conductors	:	1,0 - 2,5 mm ² , rigid and flexible
number of poles	:	12-poles
design	:	screw-type pillar terminal block with or without wire protection
material	:	polyamid natur/HT
markings	:	trademark, type designation and complete electrical ratings are pressed in the insulating material

TESTS**Test requirements**

EN 60998-1:1993
EN 60998-2-1:1993

Test results

The test results are laid down in KEMA test file 2002763/02.

Remarks


This certificate is also based on CCA Notification of Test Results CCA/DE 10052, covering TRF 2538-1440-0038/22LS3.

Conclusion

The examination proved that all test requirements were met.

Tested by : VDE

Checked by : H.L. Schendstok

**Factory-Location**

Adels-Contact GmbH & Co.K.G.,
Buchholzstrasse 40-46, BERGISCH GLADBACH, Germany

KEMA Registered Quality B.V.

Utrechtseweg 310, 6812 AR Arnhem, The Netherlands
P.O. Box 9035, 6800 ET Arnhem, The Netherlands
Telephone +31 26 3 56 28 50, Telefax +31 26 3 51 49 22