OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

OVE Testing and Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 15559-000-13 Valid from: 2021 01 28

until: 2023 01 28

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: Interpower Corporation

100 Interpower Avenue 52577-0115 Oskaloosa, Iowa United States of America

Product: Non rewirable two pole plug with dual earthing system

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: 2761, 994-667/99-NA1

Österreichischer Verband für Elektrotechnik

Head of Testing and Certification

Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2021 01 14







Certificate No.: 15559-000-13

Date: 2021 01 14 Page 2 of 3

Manufacturer:

Interpower Corporation 100 Interpower Avenue 52577-0115 Oskaloosa, Iowa United States of America

Factory location(s):

Interpower Corporation 100 Interpower Avenue 52577-0115 Oskaloosa, Iowa United States of America

Interpower Corporation 221 South Spruce Street 50140-0089 Lamoni, Iowa United States of America

Tested and certified according to:

ÖVE/ÖNORM IEC 60884-1:2005-09-01 ÖVE/ÖNORM E 8684-1:2010-03-01

Product: Non rewirable two pole plug with dual earthing system

Type designation: Trademark: Rating: 800 Rated voltage: AC 250 V Rated current: 16 A H03VV-F 3 G 0,75 800 I Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 0,75 800 Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 1 800 I Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 1,5

OVE Testing and Certification





Certificate No.: 15559-000-13

Date: 2021 01 14

Page 3 of 3

009

Rated voltage: AC 250 V Rated current: 16 A H03VV-F 3 G 0,75

009

Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 0,75

009 I

Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 1

009

Rated voltage: AC 250 V Rated current: 16 A H05VV-F 3 G 1,5