



IZLT2.E14853 Fuseholders, Cartridge Fuse - Component

If you notice a change to your IZLT2 Listing Card, click [here](#) to learn more.

[Page Bottom](#)

Fuseholders, Cartridge Fuse - Component

See General Information for Fuseholders, Cartridge Fuse - Component

COOPER BUSSMANN LLC

114 OLD STATE RD
ELLISVILLE, MO 63021 USA

E14853

Cat. No.	Voltage Rating (V)	Current Rating (A)	Withstand Rating RMS Symmetrical	Fuse Class or Size
170H1007	1000ac/dc	400	200000	Semiconductor Size 00 80 mm
170H1013	1000ac/dc	200	200000	Semiconductor Size 00 80mm
170H3003	1000ac/dc	630	200000	Semiconductor Size 3 80mm
170H3004	1000ac/dc	1250	200000	Semiconductor Size 3 80mm
170H3005	1400ac/dc	630	200000	Semiconductor Size 3 110mm
170H3006	1400ac/dc	1250	200000	Semiconductor Size 3 110mm
1A3400-09-R	480ac/dc	30	100000	13/32 inch diameter
BCCMA6033PQ-MT	600ac/dc	30	200000	10x38mm
BCCMM603-3 followed by PQ or SQ	600ac/dc	30	200000	10x38mm
BH Series Followed by 0-3, followed by 1-4, followed by 1-5	700ac/dc	700	200000	Semiconductor
BMM603 Followed by 1-4, followed by B, C, P, PQ, S, SQ	600ac/dc	30	200000	10x38mm
CH141B	750ac/dc	50	200000	14x51mm
CH141BI	750ac/dc	50	200000	14x51mm
CH141BMS	750ac/dc	50	200000	14x51mm
CH141BMS-F	750ac/dc	50	200000	14x51mm
CH141BN	750ac/dc	50	200000	14x51mm
CH141BNI	750ac/dc	50	200000	14x51mm
CH141BNMS	750ac/dc	50	200000	14x51mm
CH141BNMS-F	750ac/dc	50	200000	14x51mm
CH141BNX	750ac/dc	50	200000	14x51mm
CH141DI-48U	48dc	30	10000	14x51mm
CH141DIU	700ac/dc	50	200000	14x51mm
CH141DMSU-F	700ac/dc	50	200000	14x51mm
CH141DNIU	700ac/dc	50	200000	14x51mm
CH141DNU	700ac/dc	50	200000	14x51mm
CH141DNXU where x is replaced with 1, 2, 3 or 4	700ac/dc	50	200000	14x51mm
CH141DU	700ac/dc	50	200000	14x51mm
CH142B	750ac/dc	50	200000	14x51mm

CH142BI	750ac/dc	50	200000	14x51mm
CH142BMS	750ac/dc	50	200000	14x51mm
CH142BMS-F	750ac/dc	50	200000	14x51mm
CH142DIU	700ac/dc	50	200000	14x51mm
CH142DU	700ac/dc	50	200000	14x51mm
CH143B	750ac/dc	50	200000	14x51mm
CH143BI	750ac/dc	50	200000	14x51mm
CH143BMS	750ac/dc	50	200000	14x51mm
CH143BMS-F	750ac/dc	50	200000	14x51mm
CH143BN	750ac/dc	50	200000	14x51mm
CH143BNI	750ac/dc	50	200000	14x51mm
CH143BNMS	750ac/dc	50	200000	14x51mm
CH143BNMS-F	750ac/dc	50	200000	14x51mm
CH143DIU	700ac/dc	50	200000	14x51mm
CH143DMSU-F	700ac/dc	50	200000	14x51mm
CH143DNIU	700ac/dc	50	200000	14x51mm
CH143DNMSU-F	700ac/dc	50	200000	14x51mm
CH143DNU	700ac/dc	50	200000	14x51mm
CH143DU	700ac/dc	50	200000	14x51mm
CH144B	750ac/dc	50	200000	14x51mm
CH144BI	750ac/dc	50	200000	14x51mm
CH144BMS-F	750ac/dc	50	200000	14x51mm
CH144DIU	700ac/dc	50	200000	14x51mm
CH144DU	700ac/dc	50	200000	14x51mm
CH14BMS	750ac/dc	50	200000	14x51mm
CH221BI	750ac/dc	100	200000	22x58
CH221BI-24V	24ac/dc	100	100000	22x58
CH221BMS	750ac/dc	100	200000	22x58
CH221BMS-F	750ac/dc	100	200000	22x58
CH221BN	750ac/dc	100	200000	22x58
CH221BNI	750ac/dc	100	200000	22x58
CH221BNI-24V	24ac/dc	100	100000	22x58
CH221BNMS	750ac/dc	100	200000	22x58
CH221BNMS-F	750ac/dc	100	200000	22x58
CH221DI-48U	48dc	30	10000	22x58mm
CH221DMSU-F	700ac/dc	100	200000	22x58mm
CH221DNIU	700ac/dc	100	200000	22x58mm
CH221DNU	700ac/dc	100	200000	22x58mm
CH221DNXU where x is replaced with 1, 2, 3 or 4	700ac/dc	100	200000	22x58mm
CH221DU	700ac/dc	100	200000	22x58mm
CH222B	750ac/dc	100	200000	22x58
CH222BI	750ac/dc	100	200000	22x58
CH222BI-24V	24ac/dc	100	100000	22x58

CH222BMS	750ac/dc	100	200000	22x58
CH222BMS-F	750ac/dc	100	200000	22x58
CH222DIU	700ac/dc	100	200000	22x58mm
CH222DU	700ac/dc	100	200000	22x58mm
CH223B	750ac/dc	100	200000	22x58
CH223BI	750ac/dc	100	200000	22x58
CH223BMMS	750ac/dc	100	200000	22x58
CH223BMS	750ac/dc	100	200000	22x58
CH223BMS-F	750ac/dc	100	200000	22x58
CH223BN	750ac/dc	100	200000	22x58
CH223BNI	750ac/dc	100	200000	22x58
CH223BNMS	750ac/dc	100	200000	22x58
CH223BNMS-F	750ac/dc	100	200000	22x58
CH223DIU	700ac/dc	100	200000	22x58mm
CH223DMSU-F	700ac/dc	100	200000	22x58mm
CH223DNIU	700ac/dc	100	200000	22x58mm
CH223DNMSU-F	700ac/dc	100	200000	22x58mm
CH223DNU	700ac/dc	100	200000	22x58mm
CH223DU	700ac/dc	100	200000	22x58mm
Ch224B	750ac/dc	100	200000	22x58
CH224BI	750ac/dc	100	200000	22x58
CH224BMS	750ac/dc	100	200000	22x58
CH224DIU	700ac/dc	100	200000	22x58mm
CH224DU	700ac/dc	100	200000	22x58mm
CHM1DCIU	1000ac/dc	30	33000	Midget
CHM1DCU	1000ac/dc	30	33000	Midget
CHM1DI-48U	600dc	30	200000	Midget
CHM1DIU	600ac/dc	30	200000	Midget
CHM1DU	600ac/dc	30	200000	Midget
CHM1DXU	600ac/dc	30	200000	Midget
CHM23DU	600ac/dc	30	200000	Midget
CHM2DCIU	1000dc	30	33000	Midget
CHM2DCU	1000ac/dc	30	33000	Midget
CHM2DIU	600ac/dc	30	200000	Midget
CHM2DU	600ac/dc	30	200000	Midget
CHM3DCIU	1000dc	30	33000	Midget
CHM3DCU	1000dc	30	33000	Midget
CHM3DIU	600ac/dc	30	200000	Midget
CHM4DCIU	1000dc	30	33000	Midget
CHM4DU	600ac/dc	30	200000	Midget
CHP1I	1000dc	30	33000	Supplemental 10 x 38 mm
CHPV1	1000dc	30	33000	Supplemental 10 x 38 mm
CHPV1T	1000dc	30	33000	Supplemental 10 x 38 mm
CHPV1TI	1000dc	30	33000	Supplemental 10 x 38 mm

ECCMM603-3 followed by PQ or SQ	600ac/dc	30	200000	10x38mm
EHM1DCIU	1000dc	30	33000	Midget
EHM1DCU	1000dc	30	33000	Midget
EHM1DI-48U	600ac/dc	30	200000	Midget
EHM1DIU	600ac/dc	30	200000	Midget
EHM1DU	600ac/dc	30	200000	Midget
EHM2DCIU	1000dc	30	33000	Midget
EHM2DCU	1000dc	30	33000	Midget
EHM2DIU	600ac/dc	30	200000	Midget
EHM2DU	600ac/dc	30	200000	Midget
EHM3DCIU	1000dc	30	33000	Midget
EHM3DCU	1000dc	30	33000	Midget
EHM3DIU	600ac/dc	30	200000	Midget
EHM3DU	600ac/dc	30	200000	Midget
EHM4DCIU	1000dc	30	33000	Midget
EHM4DCU	1000dc	30	33000	Midget
EHM4DIU	600ac/dc	30	200000	Midget
EHM4DU	600ac/dc	30	200000	Midget
EHPV1	1000dc	30	33000	Supplemental 10 x 38 mm
EHPV1I	1000dc	30	33000	Supplemental 10 x 38 mm
EHPV1T	1000dc	30	33000	Supplemental 10 x 38 mm
EHPV1TI	1000dc	30	33000	Supplemental 10 x 38 mm
EMM603 followed by 1-4, followed by B, C, P, PQ, S, SQ	600ac/dc	30	200000	10x38mm
FBI may be followed by -R	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
FBI-B may be followed by -R	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
FBM may be followed by -R	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
H15-H-1	250ac/dc	10	-	Supplementary Fuses
H15-H-1B	250dc	10	-	Supplementary Fuses
H15-V-1	250ac/dc	10	-	Supplementary Fuses
H25400 followed by 1CR	250ac/dc	400	10000	H
H60400 followed by 1CR	600ac/dc	400	10000	H
HBH followed by -I or -M, may be followed by -R.	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
HBH-1K0824 may be followed by -R	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
HBV followed by -I or -M, may be followed by -R.	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
HBW followed by -I or _M, may be followed by -R.	250ac/dc	16	10000	Supplemental 1/4 in. by 1-1/4 in. or 5 x 20 mm
HEB-AA for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-AA-B for use with miscellaneous fuses sized 10x38mm.	600ac/dc	15	-	-
HEB-AB for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-

HEB-AB-B for use with miscellaneous fuses sized 10x38mm.	600ac/dc	15	-	-
HEB-AW-RLC-A for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-AW-RLC-J for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-AW-RYC for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-BB for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-BB-B for use with miscellaneous fuses sized 10x38mm.	600ac/dc	15	-	-
HEB-JJ for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-JJ-B for use with miscellaneous fuses sized 10x38mm.	600ac/dc	15	-	-
HEB-JW-RLC-J for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEB-JW-RYC for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEH-AA for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEN-KW-DRYC for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEX-AA for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HEX-AA,HEX-KW-DRYC for use with miscellaneous fuses sized 10x38mm.	600ac	30	-	-
HEX-KW-DRYC for use with miscellaneous fuses sized 10x38mm.	600ac/dc	30	-	-
HFA may be followed by -R	250ac/dc	20	-	1/4 by 1-1/4 in.
HHP-HH May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HIPS with or without suffix -F and/or -H	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in
HJM	250ac/dc	30	10000	1/4 in. by 1 in.
HJM-HH	250ac/dc	30	10000	1/4 in. by 1 in.
HKP With or without one or more suffix letters CC, E, H, L or W. with or without Z, HH, or ZZ. with or without OO. may be followed by -R.				
	250ac/dc	30	-	1/4 by 1-1/4 in.
HKP-1K0420 May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HKP-1K0956 May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HKP-1K0965 May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HLD May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HLD-00 May be followed by -R.	250ac/dc	15	-	1/4 by 1-1/4 in.
HLQ	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLQ-1K0624	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLQ-1K0662	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLR	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLR-1K0608	300ac/dc	12	-	-
HLR-1K0648	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLR-2A	300ac/dc	12	10000	5/8 in. x 1-7/8 in.
HLR-2L	300ac/dc	12	10000	5/8 in. x 1-7/8 in.

HPC-D may be followed by H	250ac/dc	15	10000	Supplemental 13/32 x 1-1/2 in.
HPD with or without suffix -F and/or -H	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in
HPF may be followed by H	250ac/dc	15	10000	Supplemental 13/32 x 1-1/2 in.
HPF-1K0555 may be followed by H	600ac/dc	25	10000	Supplemental 13/32 x 1-1/2 in.
HPF-C may be followed by H	250ac/dc	15	10000	Supplemental 13/32 x 1-1/2 in.
HPF-EE may be followed by H	600ac/dc	15	100000	G
HPF-F may be followed by H	250ac/dc	15	10000	Supplemental 13/32 x 1-1/2 in.
HPF-F-EE may be followed by H	600ac/dc	15	100000	G
HPF-FF may be followed by H	480ac/dc	30	100000	G
HPF-JJ may be followed by H	600ac/dc	20	100000	G
HPF-JJ-WT may be followed by H	600ac/dc	20	100000	G
HPF-K may be followed by H	600ac/dc	30	10000	Supplemental 13/32 x 1-1/2 in.
HPF-K-EE may be followed by H	600ac/dc	15	100000	G
HPF-K-JJ may be followed by H	600ac/dc	20	100000	G
HPF-L may be followed by H	600ac/dc	5	10000	Supplemental 13/32 x 1-1/2 in.
HPF-WT may be followed by H	600ac/dc	30	10000	Supplemental 13/32 x 1-1/2 in.
HPG - F with or without suffix -H. Suffix letters may appear in any order.	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in
HPG-1K0822 with or without suffix -F and/or -H.	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in
HPG-EE may be followed by suffix -H	600ac/dc	15	100000	G
HPM may be followed by H	600ac/dc	30	10000	Supplemental 13/32 x 1-1/2 in.
HPM-D may be followed by H	600ac/dc	30	10000	Supplemental 13/32 x 1-1/2 in.
HPN	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in inSupplemental13/32 by 1-1/2 in
HPS-EE may be followed by suffix -F and/or -H	600ac/dc	15	100000	G
HPS-FF may be followed by suffix -F and/or -H	300ac/dc	30	100000	G
HPS-JJ may be followed by suffix -F and/or -H	600ac/dc	20	100000	G
HPS-L may be followed by suffix -F and/or -H	600ac/dc	5	10000	Supplemental 13/32 x 1-3/8 in.
HPS-RR may be followed by -F and/or -H HPS RR-WT	600ac/dc	30	200000	CC
HPS-X -F with or without suffix -H. Suffix letters may appear in any order.	600ac/dc	30	10000	Supplemental13/32 by 1-1/2 in
HTB-I	300ac/dc	20	-	1/4 by 1-1/4 in
HTB-M	300ac/dc	16	-	5 by 20 mm
HTC-15M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99.				
	250ac/dc	20	-	-
HTC-30M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99.				
	250ac/dc	20	-	-
HTC-40M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99,				
	250ac/dc	20	-	-
HTC-45M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99,				

	250ac/dc	20	-	-
HTC-50M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99,				
	250ac/dc	20	-	-
HTC-70M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99,				
	250ac/dc	20	-	-
HTC-78M may be followed by A, B, C or S, may be followed by V01 through V99, may be followed by GR, NE, VE, BL, RO, AR, BI, NA, MA or GI, may be followed by N0 through N99.				
	250ac/dc	20	-	-
J60100 may be followed by 1, 2 or 3, followed by STR or STRL	600ac/dc	100	200000	J
J60200 may be followed by 1, 2 or 3, followed by STR or STRL.	600ac/dc	200	200000	J
J60400 may be followed by -1CR or -1STRM	600ac/dc	400	200000	J
J60600 may be followed by 1, 2 or 3, followed by STR or STRL.	600ac/dc	600	200000	J
PTFB-2500-JCD	250ac/dc	5	63000	0.8x4.5
PVH-AA	1000dc	30	40000	10x38mm
PVH-AB	1000dc	30	40000	10x38mm
PVH-AB-B	1000dc	15	40000	10x38mm
PVH-BB	1000dc	30	40000	10x38mm
PVH-BB-B	1000dc	15	40000	10x38mm
PVH-JJ	1000dc	30	40000	10x38mm
PVH-JJ-B	1000dc	15	40000	10x38mm
R25400 may be followed by -1CR, -1COR, -1STR or 1STRM	250ac/dc	400	200000	R
R60400 may be followed by - 1CR, -COR, -1STR or -1STRM.	600ac/dc	400	200000	R
S-800 followed by 01, 02 or 03, followed by -01 thru -12, -1-SNP or -W-SNP	300ac/dc	30	-	-
S-8000 followed by 01, 02 or 03, followed by -01 thru -12, -1-SNP or -W-SNP	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
S-8100 followed by 01, 02 or 03, followed by -01 thru -12, -1-SNP or -W-SNP	300ac/dc	20	-	-
S-8203-01	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
S-8203-1X	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
S-8301 followed by -01 thru - 12.	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
S8200 Followed by 01, 02 or 03, followed by -01 thru - 12, -1-SNP or -W-SNP.				
	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
S8300 followed by 01, 02 or 03, followed by -01 thru -12, -1-SNP.	300ac/dc	30	10000	1/4 in. by 1-1/4 in.
TCFH100NW	690ac/dc	100	50000	Cat. No. TCFxxxRNW
TCFH30NW	690ac/dc	30	50000	Cat. No. TCFxxxRNW
TCFH60NW	690ac/dc	60	50000	Cat. No. TCFxxxRNW

[Click here to view the Colombia Market Access Certification](#)



Marking: Company name or tradename "Buss" , "Fusetron" or trademark , and model designation.
Last Updated on 2017-12-01

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".