

ASTA LICENCE

ASTA DIAMOND MARK

Licence No. 767

Organization: Taller GmbH
Im Ermlisgrung 11
76337 Waldbronn
Germany

Product: General Purpose Fuse Links For Domestic & Similar Purposes

Designation: ATLAS

Characteristics: 240 Volts a.c. 50 Hz
3, 5, 10 & 13 Amperes
Breaking capacity 6kA rms
Rated power loss less than 1 watt
Constructed from lead-free materials

Approval Standard: BS 1362: 1973 plus Amendment Nos. 1 & 2

Issue Number: 8

Review Date: 28 February 2025

Factory Reference: BETTCN.A1

R.W. Hayward

Name



Signature

1 September 2020

Date

Intertek

ASTA Certificates, ASTA Licences and ASTA Test Reports

ASTA Certificates, ASTA Licences and ASTA Test Reports are issued by Intertek for the exclusive use of the party applying for the Certificate, Licence or Test Report and any related testing. Intertek assumes no liability to any parties other than those with which it has an agreement and then only in accordance with the agreed Terms and Conditions.

The Applicant is authorised to copy or distribute ASTA Certificates, ASTA Licences and

ASTA Test Reports provided the entire contents are included, or Certificate Front Sheets accompanied by any associated pages on which are stated the assigned rated characteristics and no part is obscured or illegible, or Licence front sheets. Permission must be obtained from Intertek before any other kind of reproduction is made.

The holder of an ASTA Certificate may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Certificate is ASTA Certified.

The holder of an ASTA Licence may claim in Trade Journals, Catalogues, Technical Articles etc., and without the prior approval of Intertek that the product identified in an ASTA Licence is ASTA Approved.

To minimise the possibility of any misunderstanding such claims must clearly identify the product(s) certified or approved, the ratings verified by ASTA and the Standard against which certification/approval has been made.

Any other use of the Intertek or ASTA names must first be approved in writing by Intertek. Test results and ratings proven by testing included in ASTA Certificates and ASTA Test Reports relate specifically to the sample(s) tested.

Types of ASTA Certificates

Certificates are issued when samples of a particular product design have been tested satisfactorily against the requirements of a National, European, International or ASTA Standard. Several forms of Certificate are available, including:

Certificate of Complete Compliance

Verifies compliance with all the requirements of a Standard

Certificate of Type/Verification Tests

Verifies complete series of type/verification tests prescribed in a Standard has been made successfully.

Certificate of Selected Type/Verification Tests

Verifies specified type/verification tests have been made successfully

Supplementary Certificate

Extends the scope of an existing Certificate to cover changes in rating or in design

ASTA Test Report

An ASTA Test Report is issued when tests otherwise satisfactory cannot be included in a Certificate for one or more reasons, e.g. verification of non-standard ratings

ASTA Licences and ASTA Diamond Mark

The use of the ASTA Diamond Mark on products is authorised by an ASTA Licence. Products covered by an ASTA Licence can be referred to as ASTA Approved. Requirements for ASTA Licences include testing for full compliance with relevant standards and satisfactory, on-going assessment of production. Validity and use of ASTA Licences are subject to compliance with Intertek Certification Regulations.

For more information see <https://www.intertek.com/auditing/certification-regulations-uk/>

Authenticity

Authenticity of any ASTA document can be confirmed by contacting Intertek

Email: asta@intertek.com, Tel: +44 116 296 2900

ASTA LICENCE NO.

767

Issue No.

8

ENDORSEMENT 1 OF 2

Product: General Purpose Fuse Links For Domestic & Similar Purposes

Designation: ATLAS

APPROVED SITES FOR MANUFACTURE/PRODUCTION

Dongguan Better Electronics Technology Co., Ltd
NanMen Village
Hengkeng Administrative Zone
LiaoBu Town Dongguan
Guangdong
523400, China

Conditions for maintenance of Licence:

- 1) Compliance with Certification Regulations.
- 2) Inspection of manufacturing facilities each year with satisfactory outcome.
- 3) Surveillance testing of production samples at required intervals with satisfactory outcome.
- 4) Satisfactory actions in the event of any compliance and/or safety issues becoming known after product has been supplied.
- 5) Prompt payment of invoices.

Licence Renewal:

Licence fee will be invoiced annually during the month of March.

The Licence document will be reissued following any changes advised or variants tested. A fee may be charged for reissue.

Surveillance samples:

Samples are required to be tested in accordance with Intertek surveillance testing programmes.

Samples should preferably be selected during scheduled Factory inspection visits.

The fee for testing will be invoiced at the time of testing. A summary of testing will be provided.

Use of the ASTA Mark:

The ASTA Mark may be used on the product and in marketing material relating to the product, as permitted by the Certification Regulations.

The Licence number should be marked on the product (mandatory on BS 1363 plugs, where feasible on other products) in a form agreed by Intertek, such as "Approved by ASTA Licence no. 767".

ASTA LICENCE NO.

767

Issue No.

8

ENDORSEMENT 2 OF 2

Product: General Purpose Fuse Links For Domestic & Similar Purposes

Designation: ATLAS

COMPLIANCE TESTING

Reason for test	ASTA Reference/Certificates
Complete compliance - 3 Amperes & 5 Amperes	15470-01
Complete compliance - 10 Amperes & 13 Amperes	15470-02
Complete compliance	15817
Complete compliance	16012
Complete compliance	16247
Alternative Manufacturing Site (SUNNTW.A1)	S18973
Complete compliance (HUNACN.01)	17590
Modification - alternative manufacturing site (BETTCN.A1)	S18266
Annual surveillance testing	(69971)

Approved Components, Materials and Cords:

Materials:

This Licence covers 3, 5, 10 and 13 Amperes ratings of fuse-link constructed using lead-free materials.



This Licence is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Licence. Only the Client is authorized to permit copying or distribution of this Licence and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

This Licence is accredited under UKAS, accreditation No 0010

Issued by Intertek Testing & Certification Ltd., Academy Place, 1-9 Brook Street, Brentwood CM14 5NQ, United Kingdom