

# DEMKO CERTIFICATE

**Certificate No.** D-07042  
**Page** 1/3  
**Date of Issue** 2019-01-16

**Certificate Holder** Interpower Corp.  
100 Interpower Ave, PO Box 115, Oskaloosa, IA 52577, USA

**Manufacturer** Interpower Corporation  
100 Interpower Ave, PO Box 115, Oskaloosa, IA 52577, USA

**Production site** Interpower Corporation  
100 Interpower Ave, Oskaloosa, IA 52577-0115,  
USA

See Page 2

**Certified Product Model** Two-pole plug with dual earthing contacts (non-rewirable)  
008, 009  
**Trademark**



**Rated Voltage / Frequency** 250 Vac  
**Rated Current / Power** 16 A  
**Insulation Class** -  
**Degree of protection (IP)** 20  
**Tested acc. to** DS 60884-2-D1:2017  
**Test Report No.** 4788748079.1 issued on 2018-12-03  
**Additional** See Page 2  
**Expire date** 2029-01-15

**Certification Manager**  
Jan-Erik Storgaard

This is to certify that representative sample(s) of the Product described herein ("Certified Product") have been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the D Mark Requirements. The Designated Certificate holder is entitled to use the d or for cables <DEMKO> for the Certified Product manufactured at the production site(s) identified above, in accordance with the D Mark Service Agreement, including without limitation the D Mark Testing and Certification Services Service Terms. Only those Products bearing the D Mark should be considered as being covered by UL's D Mark Service. This Certificate shall remain valid through the expiration date, unless terminated earlier in accordance with the Service Agreement including without limitation if the Standard identified on this Certificate is amended or withdrawn prior the expiration date.

**Certification Body** UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
www.ul-europe.com



# Appendix DEMKO CERTIFICATE

**Certificate No.** D-07042  
**Page** 2/3  
**Date of Issue** 2019-01-16

Production Sites:  
Interpower Corporation  
221 South Spruce St., Lamoni, IA 50140  
USA

**Additional Information:**

This certificate replaces previous certificate no. D-00193-A1, due to update the DS standard to DS 60884-2-D1:2017.

For Class I equipment  
Standard Sheet: C 4 (CEE 7 – Standard Sheet VII)

Model 008 and 009 with the following cable types:

- type 008: Plug with angled cord anchorage entry
- type 009: Plug with straight cord anchorage entry

Used cables:		
Type of cable:	Cross sectional areas:	Manufacturer:
H05VV-F	3G 0.75 mm <sup>2</sup>	Interpower
H05VV-F	3G 1.0 mm <sup>2</sup>	Interpower
H05VV-F	3G 1.5 mm <sup>2</sup>	Interpower
H03VV-F	3G 0.75 mm <sup>2</sup>	Interpower
H05VV-F	3G 0.75 mm <sup>2</sup>	Interpower
H05VV-F	3G 1.0 mm <sup>2</sup>	Interpower
H05VV-F	3G 1.5 mm <sup>2</sup>	Interpower


**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
www.ul-europe.com



# Appendix DEMKO CERTIFICATE

Certificate No. D-07042  
Page 3/3  
Date of Issue 2019-01-16



---

**Certification Body**

UL International Demko A/S, Borupvang 5A, DK-2750  
Ballerup, Denmark, Tel. +45 44 85 65 65, info.dk@ul.com  
[www.ul-europe.com](http://www.ul-europe.com)

