



Fair
Trading

Certificate Number: NSW25905

Certificate of Approval

ISSUED PURSUANT TO THE ELECTRICITY (CONSUMER SAFETY) ACT 2004

ISSUED TO: Interpower Corporation

CLASS OF ARTICLE: Appliance Connector

DESCRIPTION OF ARTICLE:

IEC 60320 C19 Non-rewireable connector

Trade Name or Mark: i

Volts: 250V

Amperes: 16A

Watts:

Hertz:

Other Name Plate Particulars:

EXAMINED FOR COMPLIANCE WITH: AS/NZS 60320.1

TYPE REFERENCE CODE: 068

APPROVAL MARK:

Each electrical article of the type described above shall be marked with Approval Number NSW25905;

or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

DATE OF APPROVAL: 31/07/2012

This approval expires 31/07/2017 unless suspended, cancelled, renewed or extended.



1.8.2012

For Commissioner for Fair Trading



Fair Trading

File Ref: NSW25905/1
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 9917

Mr Joe Caligiuri
Interpower Corporation
100 Interpower Avenue
Oskaloosa, Iowa
United States Of America 52577

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW25905

Appliance Connector

Please find enclosed an addendum to the certificate as sought in your application.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,

17 September 2013

For Commissioner for Fair Trading



Fair
Trading

Ref: NSW25905/1

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW25905 Particulars of Modification(s)

Model 069 is identical to approved Model 068 except for cord attachment of right-side-entry in lieu of straight-entry.

Model 070 is identical to approved Model 068 except for cord attachment of left-side-entry in lieu of straight-entry.

Appliance connectors Models 068, 069 and 070 are integrally moulded to any <HAR> certified H05VV-F 3G 1.0/1.5/2.5mm², or Australian approved three-core, 1.0/1.5/2.5mm², PVC insulated and sheathed ordinary duty circular flexible cord respectively.

This certificate will expire on 31/07/2017

Approved: 17 September 2013

For Commissioner for Fair Trading



Fair Trading

File Ref: NSW25905/2
Contact: Admin Clerk
Telephone: 02 9895 0722
Fax: 02 9895 9917

Mr Joe Caligiuri
Interpower Corporation
100 Interpower Avenue
Oskaloosa, Iowa
United States Of America 52577

Dear Sir/Madam

MODIFICATION TO CERTIFICATE OF APPROVAL: NSW25905

Appliance Connector

Please find enclosed an addendum to the certificate as sought in your application.

Any sample/s held by this Office should be collected within fifteen (15) days of this letter or the sample/s will be destroyed.

Yours faithfully,


For Commissioner for Fair Trading 30 June 2014



Fair
Trading

Ref: NSW25905/2

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW25905
Particulars of Modification(s)

Model 013 is identical to approved Model 068 except for cord attachment of up-side-entry in lieu of straight-entry.

Model 015 is identical to approved Model 068 except for cord attachment of down-side-entry in lieu of straight-entry.

This certificate will expire on 31/07/2017

Approved: 27 June 2014



For Commissioner for Fair Trading