

# CERTIFICATE

Issued to:  
Applicant:  
**Interpower Corporation**  
100 Interpower Avenue  
IA 52577-0115 Oskaloosa  
United States Of America

Manufacturer/Licensee:  
**Interpower Corporation**  
100 Interpower Avenue  
IA 52577-0115 Oskaloosa  
United States Of America

Product : flexible cables and cords  
Trade names : INTERPOWER  
INTERPOWER ®  
Type : H05VV-F

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 50525-1:2011 and EN 50525-2-11:2011 (Clause 4.2)
- an inspection of the production location according to CENELEC Operational Document OAG 024
- a certification agreement with the number 974041

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 13 April 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2181697/01

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



H.R.M. Barends  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	flexible cables and cords
trade names	:	INTERPOWER and INTERPOWER ®
type	:	H05VV-F
rated voltage	:	300/500 V
conductor	:	copper class 5
conductor operating temperature	:	maximum 70°C
insulation	:	PVC compound of type TI 2 to EN 50363-3
sheath	:	PVC compound of type TM 2 to EN 50363-4-1
tested cable	:	3G0,75 mm <sup>2</sup> (black sheath)
certified cables	:	3x0,75 mm <sup>2</sup> - 4,0 mm <sup>2</sup> (black sheath)

**TESTS****Test requirements**

EN 50525-1:2011

EN 50525-2-11:2011 Clause 4.2

**Test results**


The test results are laid down in DEKRA test file 2181697.01 and are based on DE1-54414/A1 and TRF No. 200258-CC5-4/A1.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : VDE

Checked by : A.A. Mackenbach

**Factory location**

Interpower Corporation  
221 South Spruce St.  
IA 50140 Lamoni  
United States Of America