


# TEST CERTIFICATE

**No. : C14 / 46656**

Client	<b>OE Electrics Ltd</b> 1 Calder Point Monckton Road Ind Estate Wakefield West Yorkshire WF2 7AL
Client contact	Mr. Charles Fox
Item(s) tested	<b>Modular Socket Stone With Swiss Front Plate</b> Models: 436#24# Rated : 10A 250V ~
Specification(s) to which above unit(s) have been tested and compliance confirmed	<b>IEC 60884-1: 2002, +A1: 2006, +A2: 2013 and deemed to comply</b>
Date of issue	4 <sup>th</sup> December 2014
Signed	 ----- <i>Giuseppe Capanna</i> ( Certifying Officer )
Relating to Project File(s) held at Nemko Ltd	44309 & 46656

To be read in conjunction with page 2 attached



Form No: QF102-1  
Issue No: 4  
Issue Date: 02.12.13





<b>Certificate No:</b>	<b>C14 / 46656</b>
<b>Client:</b>	<b>OE Electrics Ltd</b>

THIS CERTIFICATE APPLIES ONLY TO THE PARTICULAR SAMPLE UNIT(S) TESTED AND TO THE SPECIFIC TESTS CARRIED OUT AS DETAILED IN THE PROJECT FILE HELD AT NEMKO LTD.

THIS TEST CERTIFICATE DOES NOT COVER ELECTROMAGNETIC COMPATIBILITY.

IT SHOULD BE NOTED THAT ONLY A LIMITED NUMBER OF UNITS HAVE BEEN TESTED. IT IS THEREFORE ESSENTIAL FOR THE MANUFACTURER OR SUPPLIER OF THIS PRODUCT TO ENSURE THAT THE QUALITY OF ALL PRODUCTION UNITS IS OF THE SAME STANDARD AS THAT OF THE SAMPLE(S) CHECKED

WHERE FULL TESTING OF APPROVED COMPONENTS HAS NOT BEEN CARRIED OUT AS PART OF THIS REPORT, IT IS THE RESPONSIBILITY OF THE MANUFACTURER OR SUPPLIER TO ENSURE THE COMPONENTS USED IN PRODUCTION UNITS ARE AS THAT OF THE RELATED CERTIFICATES AND SUPPORTING DOCUMENTATION.

**Condition / number of test sample(s) :** Good / 14    **Serial Number(s) :** N/A

**Notes relating to this Certificate: -**    All the sockets use the same body and contact/terminal assembly, only the front plates are different.

**Project History: -**

<u>Job Number</u>	<u>Sample received</u>	<u>Job Completion Date</u>	<u>Summary of work carried out</u>
44309	19-Oct-12	23-Nov-12	Full testing on French, Belgian & German sockets
46656	13-Aug-14	29-Nov-14	Limited testing on Swiss sockets

\*\*\*\*\* END OF CERTIFICATE \*\*\*\*\*

