


# TEST CERTIFICATE

**No. : C15/47501**

Client	<b>OE Electrics Ltd</b> 1 Calder Point Monckton Road Ind Estate Wakefield West Yorkshire WF2 7AL
Client contact	Mr. Charles Fox
Item(s) tested	<b>Modular Socket Stone With Danish Front Plates</b> Models: 436#26# Rated :16A 250V ~
Specification(s) to which above unit(s) have been tested and compliance confirmed	<b>IEC 60884-1:2002+A1:2006+A2:2013 &amp; Including Danish deviations (Section 107-2-D1 4<sup>th</sup> edition ) and deemed to comply</b>
Date of issue	10 <sup>th</sup> June 2015
Signed	 ..... <i>Giuseppe Capanna</i> ( Certifying Officer )
Relating to Project File(s) held at Nemko Ltd	44309 & 47501

To be read in conjunction with page 2 attached



Form No: QF102-1  
Issue No: 5  
Issue Date: 05.12.14





<b>Certificate No:</b>	<b>C15 / 47501</b>
<b>Client:</b>	<b>OE Electrics Ltd</b>

THIS CERTIFICATE APPLIES ONLY TO THE PARTICULAR SAMPLE UNIT(S) TESTED AND TO THE SPECIFIC TESTS CARRIED OUT AS DETAILED IN THE PROJECT FILE HELD AT NEMKO LTD.

THIS TEST CERTIFICATE DOES NOT COVER ELECTROMAGNETIC COMPATIBILITY.

IT SHOULD BE NOTED THAT ONLY A LIMITED NUMBER OF UNITS HAVE BEEN TESTED. IT IS THEREFORE ESSENTIAL FOR THE MANUFACTURER OR SUPPLIER OF THIS PRODUCT TO ENSURE THAT THE QUALITY OF ALL PRODUCTION UNITS IS OF THE SAME STANDARD AS THAT OF THE SAMPLE(S) CHECKED

**Condition / number of test sample(s) :** Good / 6      **Serial Number(s) :** None

**Notes relating to this Certificate: -** none

**Project History: -**

<u>Job Number</u>	<u>Sample received</u>	<u>Job Completion Date</u>	<u>Summary of work carried out</u>
44309	19-Oct-12	23-Nov-12	Full testing (modular stone with German & French/Belgian front plate
47501	21-May-15	10-June-15	Limited testing for modular stone with Danish front plate (clauses 9, 16, 17, 19 & 21)

\*\*\*\*\* END OF CERTIFICATE \*\*\*\*\*

