



# CERTIFICATE

## FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100602R1

### Plug, non rewirable

**Type designation:** 008, 009

**Certificate holder:** Interpower Corporation  
100 Interpower Avenue  
Oskaloosa, Iowa 52577  
UNITED STATES of AMERICA

**The product complies with the standard(s):** IEC 60884-1:2002+A1+A2  
SS 428 08 34:2013+T1

**Date of expiry:** 27 April, 2026



Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 24 January, 2023

Leif Mattsson

## APPENDIX:

Reference No. SE-S-2100602R1

### Technical Data:

Type designation	008, 009
Rated voltage (V)	250~
Rated current (A)	16
Class	I
IP-Class	20
Type of cord	H05VV-F 3G0.75-1.5mm <sup>2</sup>
Standard sheet	VII
Trademark	<b>i</b>
Test Report	2100410STO-001
Product information	Non-rewirable plug, type 008 with angled- and type 009 with straight-cord entry.

### Manufacturing Sites:

Interpower Corporation  
100 Interpower Avenue  
Oskaloosa, Iowa 52577  
UNITED STATES of AMERICA

The certificate applies for countries that have sanctioned the use of plugs/outlets according to subject standard sheet and component standard.

This certificate replaces previously issued ref. No. SE-S-2100602 dated 27 April, 2021.  
A new certificate has been issued on account of removal of one Manufacturing Site.

### Certification Body:

Intertek Semko AB, Product Certification

**Place:** Kista - Stockholm

### Signed:



**Date:** 24 January, 2023

Leif Mattsson