



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2100602

Plug, non rewirable

Type designation: 008, 009

Certificate holder: Interpower Corporation
100 Interpower Avenue
Oskaloosa, Iowa, 52577
USA

The product complies with the standard(s): IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+R1+T1

Date of expiry: 27 April, 2026

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:

Henrik Wikström


Date: 27 April, 2021

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX:

Reference No. SE-S-2100602

Technical Data:

Type designation	008, 009
Rated voltage (V)	250~
Rated current (A)	16
Class	I
IP-Class	20
Type of cord	H05VV-F 3G0.75-1.5mm ²
Standard sheet	VII
Trademark	
Test Report	2100410STO-001
Product information	Non-rewirable plug, type 008 with angled- and type 009 with straight-cord entry.

Manufacturing Sites:

Interpower Corporation
221 South Spruce Street
Lamoni, Iowa 50140-0089
USA

Interpower Corporation
100 Interpower Avenue
Oskaloosa, Iowa, 52577
USA

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 27 April, 2021

Henrik Wikström