



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2200590

Miniature fuse-link

Type designation: 179120

Certificate holder: SIBA GmbH
Borker Straße 20-22
44534 Lünen
Germany

The product complies with the standard(s): EN 60127-1:2006+A1+A2
EN 60127-2:2014

Date of expiry: 31 August, 2027

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed:


Date: 12 May, 2022

Henrik Wikström

APPENDIX:

Reference No. SE-S-2200590

Technical Data:

Type designation 179120
Rated voltage (V) 250VAC
Rated current (A) 32mA, 40mA, 50mA, 63mA, 80mA, 100mA,
125mA, 160mA, 200mA, 250mA, 315mA, 400mA,
500mA, 630mA, 800mA, 1A, 1,25A, 1,6A,
2A, 2,5A, 3,15A, 4A, 5A, 6,3A.
Standard sheet 3
Trademark 
Test Report 2203790STO-001
Product information Time-lag, low-breaking capacity. Size 5 x 20 mm.

Manufacturing Sites:

SIBA GmbH
Bereich ELU-Geräteschutz
Borker Strasse 20-22
DE-44534 Lünen
GERMANY

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1710287 dated 31 August 2017. A new certificate has been issued on account of full renewal testing.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 12 May, 2022

Henrik Wikström