



**Interpower Corporation**  
**100, Interpower Avenue**  
**P.O. Box 115**  
**Oskaloosa, IA 52577**  
**UNITED STATES OF AMERICA**

Client no.  
100712

Your reference  
Joe Caligiuri


Our reference  
Christoph Meile

Date  
29.04.2020

## Authorization

Number: **20.0275**  
valid until: **28.04.2023**

Marking:



Based on the documents contained in file **20-BS-0173**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment: **Plug, non-rewirable**

Tradename: **Interpower**

Type designation **Nominal values**

**044** 250 V~ L+N+PE 16 A  
CH-type 23, standard sheet SEV 5934-2  
with non rewirable cord:  
H05VV-F 3G 1.50mm<sup>2</sup> [Helukabel]  
H05VV-F 3G 1.50mm<sup>2</sup> [Interpower]

Protection class: **for class I equipment**

Protection degree: **IP20**

Basis: **Test Report / Eurofins / 19CH-00996.S01 / 20.04.2020**

Remark:





Schweizerische Eidgenossenschaft

Confédération suisse

Confederazione Svizzera

Confederaziun svizra

Swiss Confederation

**Authorization**

Number: **20.0275**

**Test standards:**

IEC 60884-1(ed.3):2002 + A1:06 + A2:13

SN 441011-1:2019 + Corr1:19

SN 441011-2-1:2019 + Corr1:19

Federal Inspectorate for Heavy Current Installations ESTI

Peter Fluri

Head of Market Surveillance/Safety Mark

