



Schweizerische Eidgenossenschaft
Confédération suisse
Confederazione Svizzera
Confederaziun svizra

Swiss Confederation

Federal Inspectorate for Heavy Current Installations ESTI
Market Surveillance/Safety Mark

Interpower Corporation
100, Interpower Avenue
P.O. Box 115
Oskaloosa, IA 52577
UNITED STATES OF AMERICA

Client no.
100712

Your reference
Joe Caligiuri

Our reference
Peter Wylene mann

Date
08.09.2021

Authorization

Number: **21.0651**
valid until: **07.09.2024**

Marking:



PU503
Company Logo

Based on the documents contained in file **21-BS-0303**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment: **Plug, non rewirable**

Tradename: **Interpower**

Type designation **Nominal values**

043

250V~ L+N+PE 10A
CH-type 12, standard sheet 2012-2
with non rewirable cords:
H05VV-F 3G 0.75mm² [INTERPOWER]
H05VV-F 3G 1.00mm² [INTERPOWER]

Protection class: **for class I equipment**

Protection degree: **IP20**

Basis: **CoC / Eurofins / C6M22108-0032-110583 / 25.08.2021**
Test Report / Eurofins / 19CH-00999.S01 / 23.08.2021

Federal Inspectorate for Heavy Current Installations ESTI
Luppenstrasse 1, CH-8320 Fehraltorf
T +41 58 595 18 18
mub.bs.info@esti.ch
www.esti.admin.ch





Schweizerische Eidgenossenschaft
Confédération suisse
Confederazione Svizzera
Confederaziun svizra

Swiss Confederation

Authorization

Number: **21.0651**

Remark:

Test standards: IEC 60884-1(ed.3):02+A1:06+A2:13
SN 441011-1:19+corr1:19
SN 441011-2-1:19+corr1:19

Federal Inspectorate for Heavy Current Installations ESTI

Peter Fluri
Head of Market Surveillance/Safety Mark

