



Interpower Corporation
100, Interpower Avenue
P.O. Box 115
Oskaloosa, IA 52577
UNITED STATES OF AMERICA

Client no.
100712

Your reference
Joe Caligiuri

Our reference
Christoph Meile

Date
16.02.2023

Authorization



Number:
valid until:

23.0152
31.12.2024

Marking:



Based on the documents contained in file **20-BS-0173**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment: **Plug, non-rewirable**

Tradename: **Interpower**

Type designation **Nominal values**

044 250 V~ L+N+PE 16 A
CH-type 23, standard sheet 2023-2
with non rewirable cord:
H05VV-F 3G 1.50mm² [Helukabel]
H05VV-F 3G 1.50mm² [Interpower]

Protection class: for class I equipment

Protection degree: IP20

Basis: Test Report / Eurofins / 19CH-00996.S01 / 20.04.2020





Schweizerische Eidgenossenschaft
Confédération suisse
Confederazione Svizzera
Confederaziun svizra

Swiss Confederation

Authorization

Number: **23.0152**

Remark:

Test standards: IEC 60884-1(ed.3):2002 + A1:06 + A2:13
SN 441011-1:2019 + Corr1:19
SN 441011-2-1:2019 + Corr1:19

Federal Inspectorate for Heavy Current Installations ESTI

Peter Fluri
Head of Market Surveillance/Safety Mark

